

## Charles E. Schwarting Elementary School

Plainedge Union Free School District

19-45209

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
<b>PUFSD-0074</b>	1045	Room 36	Water Fountain-No Chiller	Potable	3/12/2021	<b>520</b>	Removed From Service, Pending Remediation
<b>PUFSD-0080</b>	1048	Room 40	Water Fountain-No Chiller	Potable	3/12/2021	<b>290</b>	Removed From Service, Pending Remediation
<b>PUFSD-0082</b>	1049	Room 41	Water Fountain-No Chiller	Potable	3/12/2021	<b>100</b>	Removed From Service, Pending Remediation
<b>PUFSD-0096</b>	2003	Room 50	Water Fountain-No Chiller	Potable	3/12/2021	<b>91</b>	Removed From Service, Pending Remediation
<b>PUFSD-0098</b>	2004	Room 49	Water Fountain-No Chiller	Potable	3/12/2021	<b>23</b>	Removed From Service, Pending Remediation

Eastplain Elementary School

Plainedge Union Free School District

19-45209

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
<b>PUFSD-0153</b>	1011	Room 15	Water Fountain-No Chiller	Potable	3/17/2021	<b>6200</b>	Removed From Service, Pending Remediation

John H. West Elementary School

Plainedge Union Free School District

19-45209

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
<b>PUFSD-0238</b>	1021	Room 23	Water Fountain-No Chiller	Potable	4/27/2021	<b>160</b>	Removed From Service, Pending Remediation
<b>PUFSD-0262</b>	1001	Room 40	Water Fountain-No Chiller	Potable	3/11/2021	<b>7100</b>	Removed From Service, Pending Remediation

## Plainedge High School

Plainedge Union Free School District

19-45209

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
<b>PUFSD-0580</b>	1001E	Music Suite Girls Bathroom	Bathroom Faucet	Non-Potable	3/13/2021	<b>52</b>	Placarded for Non-Drinking Use Until Remediated
<b>PUFSD-0707</b>	1023	Old Bathroom	Bathroom Faucet	Non-Potable	3/13/2021	<b>36</b>	Placarded for Non-Drinking Use Until Remediated
<b>PUFSD-0708</b>	1023	Old Bathroom	Bathroom Faucet	Non-Potable	3/13/2021	<b>150</b>	Placarded for Non-Drinking Use Until Remediated
<b>PUFSD-0710</b>	1023	Old Bathroom	Bathroom Faucet	Non-Potable	3/13/2021	<b>20</b>	Placarded for Non-Drinking Use Until Remediated
<b>PUFSD-0711</b>	1023	Old Bathroom	Bathroom Faucet	Non-Potable	3/13/2021	<b>230</b>	Placarded for Non-Drinking Use Until Remediated
<b>PUFSD-0726</b>	1001E	Music Suite Girls Bathroom	Bathroom Faucet	Non-Potable	3/13/2021	<b>35</b>	Placarded for Non-Drinking Use Until Remediated
<b>PUFSD-0738</b>	1032	Library	Kitchen Faucet (Cold)	Potable	4/27/2021	<b>16</b>	Removed From Service, Pending Remediation

Plainedge Middle School

Plainedge Union Free School District

19-45209

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
PUFSD-0333	N/A New Construction	Boy's Restroom o/s Room C339	Bathroom Faucet	Non-Potable	3/16/2021	18	Placarded for Non-Drinking Use Until Remediated
PUFSD-0400	N/A New Construction	Girl's Restroom o/s C205	Bathroom Faucet	Non-Potable	3/16/2021	38	Placarded for Non-Drinking Use Until Remediated
PUFSD-0401	N/A New Construction	Girl's Restroom o/s C205	Bathroom Faucet	Non-Potable	3/16/2021	32	Placarded for Non-Drinking Use Until Remediated
PUFSD-0405	N/A New Construction	Boy's Restroom o/s Room C205	Bathroom Faucet	Non-Potable	3/16/2021	17	Placarded for Non-Drinking Use Until Remediated
PUFSD-0407	N/A New Construction	Boy's Restroom o/s Room C205	Bathroom Faucet	Non-Potable	3/16/2021	27	Placarded for Non-Drinking Use Until Remediated
PUFSD-0410	N/A New Construction	Room C201 Technology	Science Faucet	Non-Potable	3/16/2021	140	Outlet Use Determined to be Non-Applicable, Placarded for Non-Drinking Use, Continue O&M
PUFSD-0438	N/A New Construction	Robotoics Lab A107	Science Faucet	Non-Potable	3/16/2021	30	Outlet Use Determined to be Non-Applicable, Placarded for Non-Drinking Use, Continue O&M
PUFSD-0439	N/A New Construction	Robotoics Lab A107	Science Faucet	Non-Potable	3/16/2021	120	Outlet Use Determined to be Non-Applicable, Placarded for Non-Drinking Use, Continue O&M
PUFSD-0451	N/A New Construction	Kitchen	Kitchen Non Potable	Non-Potable	3/16/2021	60	Placarded for Non-Drinking Use Until Remediated
PUFSD-0453	N/A New Construction	Kitchen	Kitchen Non Potable	Non-Potable	3/16/2021	33	Placarded for Non-Drinking Use Until Remediated